

# **Sample Reports**

## **for**

# **HAP 6.0 Example Problem**



Carrier Software Systems  
Carrier Corporation  
Syracuse, New York

rev November 23, 2022

© 2022 Carrier. All Rights Reserved

# Introduction

---

This document contains reports generated using the Carrier Hourly Analysis Program (HAP) 6.0 example problem. These reports have two uses:

- When working through the example problem in the help system as a means of learning the software. The following pages contain design load and energy modeling output reports as well as input data reports.
- When validating the installation of HAP by comparing example problem results calculated on your computer versus the reference results shown in the reports on the following pages. This type of validation verifies the software is properly installed and functioning on your computer. Some companies require this validation before accepting the software.

To review example problem reports for either purpose:

1. Start HAP.
2. If this is the first time running HAP:
  - a. A new, untitled project will be created automatically.
  - b. From the main window select the Open option on the Project menu.
  - c. Navigate to the C:\Users\Public\Public Documents\Carrier Hourly Analysis Program folder. Select the *HAP60-Example-Problem.hap* project file found in this folder.
3. If HAP has been run previously and other projects have been created:
  - a. Press the Browse button on the Open Project window that appears during startup.
  - b. Navigate to the C:\Users\Public\Public Documents\Carrier Hourly Analysis Program folder. Select the *HAP60-Example-Problem.hap* project file in this folder.
4. Generate the set of design load reports found on the following pages.
  - a. In the main window, click Alternatives in the left-hand navigation panel.
  - b. In the right-hand list panel right-click the single alternative name. Select the Print/View Design Load Reports option on the pop-up menu that appears.
  - c. In the Report selection window select the set of system design load reports shown on the following pages. Press Preview to view the reports. After the reports display you can save them to disk or print them.
5. Generate the set of energy modeling reports found on the following pages.
  - a. In the main window, click Alternatives in the left-hand navigation panel.
  - b. In the right-hand list panel right-click the single alternative name. Select the Print/View Energy Modeling Reports option on the pop-up menu that appears.
  - c. In the Report selection window select the set of alternative and system reports shown on the following pages. Press Preview to view the reports. After the reports display you can save them to disk or print them.
6. If performing validation, compare your results with the reference results on the following pages.
  - a. If the results match, then your installation is validated.
  - b. If the results do not match, please send an e-mail to the software support help desk ([software.systems@carrier.com](mailto:software.systems@carrier.com)) explaining your problem and attaching this PDF, the HAP60-Example-Problem.hap project file you used, and the reports you generated which do not match the reference results.

# **Selected Design Load Reports**

# Air System Sizing Summary for VAV - Wing D

(In Alternative: ALT1 - VAV RTU)

Project: HAP60-Example-Problem

11/23/2022

Prepared by: Carrier

4:10 PM

## Air System Information

Air System Name ..... VAV - Wing D  
Equipment Class ..... PKG ROOF  
Air System Type ..... VAV

Number of zones ..... 11  
Floor Area ..... 9274.3 sqft  
Location ..... Indianapolis Intl, IN, USA

## Sizing Calculation Information

Calculation Months ..... May to Nov  
Sizing Data ..... Calculated

Zone CFM Sizing ..... Peak zone sensible load  
Space CFM Sizing ..... Individual peak space loads

## Central Cooling Coil Sizing Data

Total coil load ..... 30.0 Tons  
Total coil load ..... 360.4 MBH  
Sensible coil load ..... 208.6 MBH  
Coil CFM at peak load ..... 6218 CFM  
Sum of peak zone CFM ..... 6867 CFM  
Sensible heat ratio ..... 0.579  
CFM/Ton ..... 207.0  
sqft/Ton ..... 308.8  
BTU/(hr sqft) ..... 38.9  
Water flow @ 10.0 F rise ..... N/A

Peak coil load occurs at ..... August 16:00  
OA DB / WB ..... 91.3 / 75.0 F  
Entering DB / WB ..... 85.1 / 70.8 F  
Leaving DB / WB ..... 53.7 / 52.3 F  
Resulting RH ..... 50 %  
Design supply temp. .... 55.0 F  
Zone T-stat Check ..... 11 of 11 OK  
Max zone temperature deviation ..... 0.0 F

## Preheat Coil Sizing Data

Max coil load ..... 197.9 MBH  
Coil CFM at Design Heating ..... 4093 CFM  
Max coil CFM ..... 6429 CFM  
Water flow @ 20.0 F drop ..... N/A

Load occurs at ..... Design Heating  
Ent. DB / Lvg DB ..... 5.9 / 52.0 F

## Supply Fan Sizing Data

Design CFM ..... 6429 CFM  
Design CFM occurs at ..... August 17:00  
Design CFM/sqft ..... 0.69 CFM/sqft  
Sum of peak zone CFM ..... 6867 CFM  
VAV Fan Diversity ..... 6.4 %

Fan motor BHP ..... 3.52 BHP  
Fan motor kW ..... 2.79 kW  
Fan total static ..... 2.00 in wg

## Outdoor Ventilation Air Data

Design airflow CFM ..... 3882 CFM  
CFM/sqft ..... 0.42 CFM/sqft

CFM/person ..... 18.58 CFM/person

## Zone Sizing Summary for VAV - Wing D (In Alternative: ALT1 - VAV RTU)

Project: HAP60-Example-Problem

11/23/2022

Prepared by: Carrier

4:10 PM

### Air System Information

Air System Name ..... VAV - Wing D  
Equipment Class ..... PKG ROOF  
Air System Type ..... VAV

Number of zones ..... 11  
Floor Area ..... 9274.3 sqft  
Location ..... Indianapolis Intl, IN, USA

### Sizing Calculation Information

Calculation Months ..... May to Nov  
Sizing Data ..... Calculated

Zone CFM Sizing ..... Peak zone sensible load  
Space CFM Sizing ..... Individual peak space loads

### Zone Terminal Sizing Data

| Zone Name              | Design Supply Airflow (CFM) | Minimum Supply Airflow (CFM) | Zone CFM/sqft | Reheat Coil Capacity (MBH) | Reheat Coil Water gpm @ 20.0 F | Zone Htg Unit Coil Capacity (MBH) | Zone Htg Unit Water gpm @ 20.0 F | Mixing Box Fan Airflow (CFM) |
|------------------------|-----------------------------|------------------------------|---------------|----------------------------|--------------------------------|-----------------------------------|----------------------------------|------------------------------|
| D101 - Classroom       | 741                         | 456                          | 0.85          | 16.8                       | -                              | 0.0                               | -                                | 0                            |
| D102 - Classroom       | 724                         | 449                          | 0.88          | 16.5                       | -                              | 0.0                               | -                                | 0                            |
| D103 - Classroom       | 749                         | 459                          | 0.84          | 16.9                       | -                              | 0.0                               | -                                | 0                            |
| D104 - Classroom       | 751                         | 459                          | 0.84          | 16.8                       | -                              | 0.0                               | -                                | 0                            |
| D105 - South Vestibule | 128                         | 32                           | 1.98          | 4.7                        | -                              | 0.0                               | -                                | 0                            |
| D106 - Classroom       | 842                         | 455                          | 0.97          | 16.7                       | -                              | 0.0                               | -                                | 0                            |
| D107 - Classroom       | 803                         | 457                          | 0.92          | 16.8                       | -                              | 0.0                               | -                                | 0                            |
| D108 - Classroom       | 1469                        | 931                          | 0.72          | 34.2                       | -                              | 0.0                               | -                                | 0                            |
| D112 - West Vestibule  | 137                         | 34                           | 2.01          | 5.0                        | -                              | 0.0                               | -                                | 0                            |
| D113 - West Corridor   | 270                         | 71                           | 0.28          | 3.5                        | -                              | 0.0                               | -                                | 0                            |
| D114 - South Corridor  | 254                         | 70                           | 0.27          | 3.2                        | -                              | 0.0                               | -                                | 0                            |

### Zone Peak Sensible Loads

| Zone Name              | Zone Cooling Sensible (MBH) | Time of Peak Sensible Cooling Load | Zone Heating Load (MBH) | Zone Floor Area (sqft) |
|------------------------|-----------------------------|------------------------------------|-------------------------|------------------------|
| D101 - Classroom       | 15.6                        | July 11:00                         | 5.2                     | 873.4                  |
| D102 - Classroom       | 15.2                        | July 11:00                         | 5.0                     | 825.7                  |
| D103 - Classroom       | 15.7                        | July 11:00                         | 5.5                     | 892.2                  |
| D104 - Classroom       | 15.8                        | July 11:00                         | 7.2                     | 890.0                  |
| D105 - South Vestibule | 2.2                         | November 13:00                     | 2.7                     | 64.6                   |
| D106 - Classroom       | 17.7                        | July 18:00                         | 7.6                     | 864.4                  |
| D107 - Classroom       | 16.8                        | July 18:00                         | 5.3                     | 877.1                  |
| D108 - Classroom       | 30.8                        | August 16:00                       | 10.1                    | 2029.3                 |
| D112 - West Vestibule  | 2.9                         | August 18:00                       | 2.8                     | 68.0                   |
| D113 - West Corridor   | 5.7                         | July 7:00                          | 2.0                     | 949.7                  |
| D114 - South Corridor  | 5.3                         | July 7:00                          | 1.8                     | 939.9                  |

### Space Loads and Airflows

| Zone Name / Space Name  | Cooling Sensible (MBH) | Time of Peak Sensible Load | Air Flow (CFM) | Heating Load (MBH) | Floor Area (sqft) | Space CFM/sqft |
|-------------------------|------------------------|----------------------------|----------------|--------------------|-------------------|----------------|
| <b>D101 - Classroom</b> |                        |                            |                |                    |                   |                |
| D101 - Classroom        | 15.6                   | July 11:00                 | 741            | 5.2                | 873.4             | 0.85           |
| <b>D102 - Classroom</b> |                        |                            |                |                    |                   |                |
| D102 - Classroom        | 15.2                   | July 11:00                 | 724            | 5.0                | 825.7             | 0.88           |
| <b>D103 - Classroom</b> |                        |                            |                |                    |                   |                |
| D103 - Classroom        | 15.7                   | July 11:00                 | 749            | 5.5                | 892.2             | 0.84           |
| <b>D104 - Classroom</b> |                        |                            |                |                    |                   |                |
| D104 - Classroom        | 15.8                   | July 11:00                 | 751            | 7.2                | 890.0             | 0.84           |

## Zone Sizing Summary for VAV - Wing D

(In Alternative: ALT1 - VAV RTU)

Project: HAP60-Example-Problem

11/23/2022

Prepared by: Carrier

4:10 PM

| Zone Name /<br>Space Name     | Cooling<br>Sensible<br>(MBH) | Time of<br>Peak<br>Sensible<br>Load | Air<br>Flow<br>(CFM) | Heating<br>Load<br>(MBH) | Floor<br>Area<br>(sqft) | Space<br>CFM/sqft |
|-------------------------------|------------------------------|-------------------------------------|----------------------|--------------------------|-------------------------|-------------------|
| <b>D105 - South Vestibule</b> |                              |                                     |                      |                          |                         |                   |
| D105 - South Vestibule        | 2.2                          | November 13:00                      | 128                  | 2.7                      | 64.6                    | 1.98              |
| <b>D106 - Classroom</b>       |                              |                                     |                      |                          |                         |                   |
| D106 - Classroom              | 17.7                         | July 18:00                          | 842                  | 7.6                      | 864.4                   | 0.97              |
| <b>D107 - Classroom</b>       |                              |                                     |                      |                          |                         |                   |
| D107 - Classroom              | 16.8                         | July 18:00                          | 803                  | 5.3                      | 877.1                   | 0.92              |
| <b>D108 - Classroom</b>       |                              |                                     |                      |                          |                         |                   |
| D108 - Classroom              | 27.4                         | August 16:00                        | 1303                 | 7.0                      | 1712.7                  | 0.76              |
| D111 - Office                 | 1.9                          | July 7:00                           | 92                   | 1.2                      | 146.0                   | 0.63              |
| D110 - Storage                | 0.9                          | July 19:00                          | 41                   | 1.0                      | 109.6                   | 0.38              |
| D109 - Practice Room          | 1.2                          | August 18:00                        | 56                   | 0.9                      | 61.0                    | 0.91              |
| <b>D112 - West Vestibule</b>  |                              |                                     |                      |                          |                         |                   |
| D112 - West Vestibule         | 2.9                          | August 18:00                        | 137                  | 2.8                      | 68.0                    | 2.01              |
| <b>D113 - West Corridor</b>   |                              |                                     |                      |                          |                         |                   |
| D113 - West Corridor          | 5.7                          | July 7:00                           | 270                  | 2.0                      | 949.7                   | 0.28              |
| <b>D114 - South Corridor</b>  |                              |                                     |                      |                          |                         |                   |
| D114 - South Corridor         | 5.3                          | July 7:00                           | 254                  | 1.8                      | 939.9                   | 0.27              |

## Ventilation Sizing Summary for VAV - Wing D

### (In Alternative: ALT1 - VAV RTU)

Project: HAP60-Example-Problem  
Prepared by: Carrier

11/23/2022  
4:10 PM

#### 1. Summary

Ventilation Sizing Method ..... ASHRAE Standard 62.1-2016  
Design Condition ..... Minimum flow (heating)  
Occupant Diversity (D) ..... 1.000  
Uncorrected Outdoor Air Intake (Vou) ..... 3053 CFM  
System Ventilation Efficiency (Ev) ..... 0.786  
Outdoor Air Intake (Vot) ..... 3882 CFM

#### 2. Space Ventilation Analysis

|                               | Minimum<br>Supply<br>Air<br>(CFM) | Space Floor<br>Area<br>(sqft) | Area Outdoor<br>Air Rate<br>(CFM/sqft) | Time<br>Averaged<br>Occupancy<br>(Occupants) | People<br>Outdoor Air<br>Rate<br>(CFM/person) | Air<br>Distribution<br>Effectiveness | Space<br>Outdoor Air<br>(CFM) | Breathing<br>Zone<br>Outdoor Air<br>(CFM) | Space<br>Ventilation<br>Efficiency |
|-------------------------------|-----------------------------------|-------------------------------|----------------------------------------|----------------------------------------------|-----------------------------------------------|--------------------------------------|-------------------------------|-------------------------------------------|------------------------------------|
| Zone Name / Space Name        | (Vpz)                             | (Az)                          | (Ra)                                   | (Pz)                                         | (Rp)                                          | (Ez)                                 | (Voz)                         | (Vbz)                                     | (Evz)                              |
| <b>D101 - Classroom</b>       |                                   |                               |                                        |                                              |                                               |                                      |                               |                                           |                                    |
| D101 - Classroom              | 456                               | 873.4                         | 0.12                                   | 26.0                                         | 10.00                                         | 0.80                                 | 456                           | 365                                       | 0.786                              |
| <b>D102 - Classroom</b>       |                                   |                               |                                        |                                              |                                               |                                      |                               |                                           |                                    |
| D102 - Classroom              | 449                               | 825.7                         | 0.12                                   | 26.0                                         | 10.00                                         | 0.80                                 | 449                           | 359                                       | 0.786                              |
| <b>D103 - Classroom</b>       |                                   |                               |                                        |                                              |                                               |                                      |                               |                                           |                                    |
| D103 - Classroom              | 459                               | 892.2                         | 0.12                                   | 26.0                                         | 10.00                                         | 0.80                                 | 459                           | 367                                       | 0.786                              |
| <b>D104 - Classroom</b>       |                                   |                               |                                        |                                              |                                               |                                      |                               |                                           |                                    |
| D104 - Classroom              | 459                               | 890.0                         | 0.12                                   | 26.0                                         | 10.00                                         | 0.80                                 | 459                           | 367                                       | 0.786                              |
| <b>D105 - South Vestibule</b> |                                   |                               |                                        |                                              |                                               |                                      |                               |                                           |                                    |
| D105 - South Vestibule        | 32                                | 64.6                          | 0.06                                   | 0.0                                          | 0.00                                          | 0.80                                 | 5                             | 4                                         | 1.635                              |
| <b>D106 - Classroom</b>       |                                   |                               |                                        |                                              |                                               |                                      |                               |                                           |                                    |
| D106 - Classroom              | 455                               | 864.4                         | 0.12                                   | 26.0                                         | 10.00                                         | 0.80                                 | 455                           | 364                                       | 0.786                              |
| <b>D107 - Classroom</b>       |                                   |                               |                                        |                                              |                                               |                                      |                               |                                           |                                    |
| D107 - Classroom              | 457                               | 877.1                         | 0.12                                   | 26.0                                         | 10.00                                         | 0.80                                 | 457                           | 365                                       | 0.786                              |
| <b>D108 - Classroom</b>       |                                   |                               |                                        |                                              |                                               |                                      |                               |                                           |                                    |
| D108 - Classroom              | 894                               | 1712.7                        | 0.12                                   | 51.0                                         | 10.00                                         | 0.80                                 | 894                           | 716                                       | 0.786                              |
| D111 - Office                 | 23                                | 146.0                         | 0.06                                   | 1.0                                          | 5.00                                          | 0.80                                 | 17                            | 14                                        | 1.025                              |
| D110 - Storage                | 10                                | 109.6                         | 0.06                                   | 0.0                                          | 5.00                                          | 0.80                                 | 8                             | 7                                         | 0.981                              |
| D109 - Practice Room          | 14                                | 61.0                          | 0.06                                   | 1.0                                          | 5.00                                          | 0.80                                 | 11                            | 9                                         | 0.996                              |
| <b>D112 - West Vestibule</b>  |                                   |                               |                                        |                                              |                                               |                                      |                               |                                           |                                    |
| D112 - West Vestibule         | 34                                | 68.0                          | 0.06                                   | 0.0                                          | 0.00                                          | 0.80                                 | 5                             | 4                                         | 1.637                              |
| <b>D113 - West Corridor</b>   |                                   |                               |                                        |                                              |                                               |                                      |                               |                                           |                                    |
| D113 - West Corridor          | 71                                | 949.7                         | 0.06                                   | 0.0                                          | 0.00                                          | 0.80                                 | 71                            | 57                                        | 0.786                              |
| <b>D114 - South Corridor</b>  |                                   |                               |                                        |                                              |                                               |                                      |                               |                                           |                                    |
| D114 - South Corridor         | 70                                | 939.9                         | 0.06                                   | 0.0                                          | 0.00                                          | 0.80                                 | 70                            | 56                                        | 0.786                              |
| <b>Totals</b>                 | <b>3882</b>                       |                               |                                        |                                              |                                               |                                      |                               | <b>3053</b>                               | <b>0.786</b>                       |

## Air System Heat Balance Summary for VAV - Wing D (In Alternative: ALT1 - VAV RTU)

Project: HAP60-Example-Problem  
Prepared by: Carrier

11/23/2022  
4:10 PM

**Table 1. System Loads**

|                         | DESIGN COOLING - AUGUST 16:00                                          |                   |                 | DESIGN HEATING                                                         |                   |                 |
|-------------------------|------------------------------------------------------------------------|-------------------|-----------------|------------------------------------------------------------------------|-------------------|-----------------|
|                         | OA DB / WB 91.3 F / 75.0 F                                             |                   |                 | OA DB / WB 2.6 F / 0.9 F                                               |                   |                 |
| COMPONENT LOADS         | Details                                                                | Sensible [BTU/hr] | Latent [BTU/hr] | Details                                                                | Sensible [BTU/hr] | Latent [BTU/hr] |
| Zone Conditioning       | -                                                                      | 133105            | 41447           | -                                                                      | 55610             | 0               |
| Plenum Load             | -                                                                      | 0                 | 0               | -                                                                      | 0                 | 0               |
| Return Fan Load         | 6218 CFM                                                               | 0                 | -               | 4093 CFM                                                               | 0                 | -               |
| Ventilation Load        | 3882 CFM                                                               | 65702             | 103867          | 3882 CFM                                                               | 274245            | 0               |
| Supply Fan Load         | 6218 CFM                                                               | 8759              | -               | 4093 CFM                                                               | -3612             | -               |
| Zone Fan Coil Fans Load | -                                                                      | 0                 | -               | -                                                                      | 0                 | -               |
| >> Total System Loads   | -                                                                      | 207565            | 145314          | -                                                                      | 326243            | 0               |
| Central Cooling Coil    | -                                                                      | 208648            | 151751          | -                                                                      | 0                 | 0               |
| Preheat Coil            | -                                                                      | 0                 | -               | -                                                                      | 197944            | -               |
| Terminal Reheat Coils   | -                                                                      | 0                 | -               | -                                                                      | 129156            | -               |
| >> Total Conditioning   | -                                                                      | 208648            | 151751          | -                                                                      | 327099            | 0               |
| Key:                    | Positive values are cooling loads<br>Negative values are heating loads |                   |                 | Positive values are heating loads<br>Negative values are cooling loads |                   |                 |

**Table 2. Zone Heat Balance Loads**

|                               | DESIGN COOLING - AUGUST 16:00                                          |                   |                 | DESIGN HEATING                                                         |                   |                 |
|-------------------------------|------------------------------------------------------------------------|-------------------|-----------------|------------------------------------------------------------------------|-------------------|-----------------|
|                               | OA DB / WB 91.3 F / 75.0 F                                             |                   |                 | OA DB / WB 2.6 F / 0.9 F                                               |                   |                 |
| Zone Heat Balance Component   | Details                                                                | Sensible [BTU/hr] | Latent [BTU/hr] | Details                                                                | Sensible [BTU/hr] | Latent [BTU/hr] |
| Exterior Wall Convection      | 2343 sqft                                                              | 8355              | -               | 2343 sqft                                                              | 6667              | -               |
| Roof Convection               | 0 sqft                                                                 | 0                 | -               | 0 sqft                                                                 | 0                 | -               |
| Window Convection             | 441 sqft                                                               | 3955              | -               | 441 sqft                                                               | 4741              | -               |
| Skylight Convection           | 0 sqft                                                                 | 0                 | -               | 0 sqft                                                                 | 0                 | -               |
| Door Convection               | 95 sqft                                                                | 911               | -               | 95 sqft                                                                | 2581              | -               |
| Floor Convection              | 9274 sqft                                                              | 24404             | -               | 9274 sqft                                                              | 15169             | -               |
| Interior Wall Convection      | 9837 sqft                                                              | 16099             | -               | 9837 sqft                                                              | 4964              | -               |
| Ceiling Convection            | 9274 sqft                                                              | 39682             | -               | 9274 sqft                                                              | 20825             | -               |
| Overhead Lighting Convection  | 5372 W                                                                 | 8138              | -               | 0 W                                                                    | 0                 | -               |
| Task Lighting Convection      | 0 W                                                                    | 0                 | -               | 0 W                                                                    | 0                 | -               |
| Electric Equipment Convection | 6397 W                                                                 | 16371             | -               | 0 W                                                                    | 0                 | -               |
| People Convection             | 209                                                                    | 15362             | 42845           | 0                                                                      | 0                 | 0               |
| Infiltration                  | 5 CFM                                                                  | 81                | 130             | 6 CFM                                                                  | 402               | 0               |
| Miscellaneous Equipment       | -                                                                      | 0                 | 0               | -                                                                      | 0                 | 0               |
| Air Internal Energy Change    | -                                                                      | 0                 | -               | -                                                                      | 0                 | 0               |
| Safety Factor                 | 0% / 0%                                                                | 0                 | 0               | 0%                                                                     | 0                 | 0               |
| >> Total Zone Loads           | -                                                                      | 133358            | 42975           | -                                                                      | 55349             | 0               |
| Key:                          | Positive values are cooling loads<br>Negative values are heating loads |                   |                 | Positive values are heating loads<br>Negative values are cooling loads |                   |                 |

- Note 1:** Surface convection line items show the combined effects of conductive heat gain to the surface and radiative heat gains absorbed at the surface which are then convected to room air.
- Note 2:** Lighting, equipment, and people line items include only the direct convective heat gain from the heat source to the room air. The radiative portion of the heat gain is first absorbed by surfaces in the room and then later convected from the surface to the air. Therefore the effect of the radiative portion of the heat gain is found in the surface convection line items.
- Note 3:** Solar heat gain is absorbed by surfaces in the room, re-radiated to other surfaces, and finally convected from the surfaces to room air. Therefore, the effect of solar heat gain is found in the surface convection line items.




# **Selected Energy Modeling Reports**

## Annual Component Costs - ALT1 - VAV RTU

Project: HAP60-Example-Problem  
Prepared by: Carrier

11/23/2022  
4:10 PM



### 1. Annual Costs

| Component                 | Annual Cost (\$) | (\$/sqft)    | Percent of Total (%) |
|---------------------------|------------------|--------------|----------------------|
| Air System Fans           | 646              | 0.070        | 3.9                  |
| Cooling                   | 1,974            | 0.213        | 11.9                 |
| Heating                   | 10,213           | 1.101        | 61.7                 |
| Pumps                     | 0                | 0.000        | 0.0                  |
| Heat Rejection Fans       | 0                | 0.000        | 0.0                  |
| <b>HVAC Sub-Total</b>     | <b>12,833</b>    | <b>1.384</b> | <b>77.5</b>          |
| Lights                    | 2,075            | 0.224        | 12.5                 |
| Electric Equipment        | 1,649            | 0.178        | 10.0                 |
| Misc. Electric            | 0                | 0.000        | 0.0                  |
| Misc. Fuel Use            | 0                | 0.000        | 0.0                  |
| <b>Non-HVAC Sub-Total</b> | <b>3,723</b>     | <b>0.402</b> | <b>22.5</b>          |
| <b>Grand Total</b>        | <b>16,557</b>    | <b>1.785</b> | <b>100.0</b>         |

Note: Cost per unit floor area is based on the gross building floor area.

Gross Floor Area ..... **9,274.3** sqft  
Modeled Floor Area ..... **9,274.3** sqft

## Monthly Energy Use by Component - ALT1 - VAV RTU

Project: HAP60-Example-Problem  
Prepared by: Carrier

11/23/2022  
4:10 PM

### 1. Monthly Energy Use by System Component

| Component             | Jan   | Feb   | Mar   | Apr  | May  | Jun  | Jul  | Aug  | Sep  | Oct  | Nov   | Dec   |
|-----------------------|-------|-------|-------|------|------|------|------|------|------|------|-------|-------|
| Air System Fans (kWh) | 744   | 653   | 661   | 432  | 367  | 315  | 182  | 286  | 354  | 468  | 586   | 717   |
| <i>Cooling</i>        |       |       |       |      |      |      |      |      |      |      |       |       |
| Electric (kWh)        | 24    | 72    | 368   | 627  | 2819 | 3882 | 1680 | 3401 | 3416 | 1174 | 140   | 10    |
| Natural Gas (na)      | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Fuel Oil (na)         | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Propane (na)          | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Remote HW (na)        | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Remote Steam (na)     | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Remote CW (na)        | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| <i>Heating</i>        |       |       |       |      |      |      |      |      |      |      |       |       |
| Electric (kWh)        | 21509 | 15948 | 11949 | 4718 | 1901 | 343  | 0    | 160  | 563  | 4948 | 10470 | 18592 |
| Natural Gas (na)      | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Fuel Oil (na)         | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Propane (na)          | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Remote HW (na)        | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Remote Steam (na)     | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Pumps (kWh)           | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Heat Rej. Fans (kWh)  | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Lighting (kWh)        | 1789  | 1691  | 1929  | 1435 | 1789 | 1564 | 296  | 1218 | 1780 | 1795 | 1710  | 1509  |
| Electric Eqpt. (kWh)  | 1422  | 1343  | 1533  | 1139 | 1422 | 1244 | 238  | 969  | 1414 | 1425 | 1358  | 1199  |
| Misc. Electric (kWh)  | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| <i>Misc. Fuel</i>     |       |       |       |      |      |      |      |      |      |      |       |       |
| Natural Gas (na)      | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Fuel Oil (na)         | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Propane (na)          | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Remote HW (na)        | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |
| Remote Steam (na)     | 0     | 0     | 0     | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0     | 0     |

## Billing Details - Electric - ALT1 - VAV RTU

Project: HAP60-Example-Problem  
Prepared by: Carrier

11/23/2022  
4:10 PM

### 1. Component Charges

| Billing Period | Energy Charges (\$) | Demand Charges (\$) | Customer Charges (\$) | Taxes (\$) | Total Charge (\$) |
|----------------|---------------------|---------------------|-----------------------|------------|-------------------|
| Jan            | 2,857               | 0                   | 0                     | 0          | 2,857             |
| Feb            | 2,209               | 0                   | 0                     | 0          | 2,209             |
| Mar            | 1,843               | 0                   | 0                     | 0          | 1,843             |
| Apr            | 936                 | 0                   | 0                     | 0          | 936               |
| May            | 930                 | 0                   | 0                     | 0          | 930               |
| Jun            | 824                 | 0                   | 0                     | 0          | 824               |
| Jul            | 269                 | 0                   | 0                     | 0          | 269               |
| Aug            | 677                 | 0                   | 0                     | 0          | 677               |
| Sep            | 844                 | 0                   | 0                     | 0          | 844               |
| Oct            | 1,100               | 0                   | 0                     | 0          | 1,100             |
| Nov            | 1,599               | 0                   | 0                     | 0          | 1,599             |
| Dec            | 2,469               | 0                   | 0                     | 0          | 2,469             |
| <b>Totals</b>  | 16,557              | 0                   | 0                     | 0          | 16,557            |

### 2. Totals

| Billing Period | Total Charges (\$) | Total Consumption (kWh) | Avg Price (\$/kWh) |
|----------------|--------------------|-------------------------|--------------------|
| Jan            | 2,857              | 25,489                  | 0.1121             |
| Feb            | 2,209              | 19,706                  | 0.1121             |
| Mar            | 1,843              | 16,441                  | 0.1121             |
| Apr            | 936                | 8,351                   | 0.1121             |
| May            | 930                | 8,299                   | 0.1121             |
| Jun            | 824                | 7,348                   | 0.1121             |
| Jul            | 269                | 2,397                   | 0.1121             |
| Aug            | 677                | 6,035                   | 0.1121             |
| Sep            | 844                | 7,527                   | 0.1121             |
| Oct            | 1,100              | 9,810                   | 0.1121             |
| Nov            | 1,599              | 14,264                  | 0.1121             |
| Dec            | 2,469              | 22,027                  | 0.1121             |
| <b>Totals</b>  | 16,557             | 147,695                 | 0.1121             |

## Billing Details - Electric - ALT1 - VAV RTU

Project: HAP60-Example-Problem  
Prepared by: Carrier

11/23/2022  
4:10 PM

### 3. Consumption Totals

| Billing Period | Peak (kWh) | Mid-Peak (kWh) | Normal Peak (kWh) | Off-Peak (kWh) | Overall (kWh) |
|----------------|------------|----------------|-------------------|----------------|---------------|
| Jan            | 0          | 0              | 0                 | 0              | 25,489        |
| Feb            | 0          | 0              | 0                 | 0              | 19,706        |
| Mar            | 0          | 0              | 0                 | 0              | 16,441        |
| Apr            | 0          | 0              | 0                 | 0              | 8,351         |
| May            | 0          | 0              | 0                 | 0              | 8,299         |
| Jun            | 0          | 0              | 0                 | 0              | 7,348         |
| Jul            | 0          | 0              | 0                 | 0              | 2,397         |
| Aug            | 0          | 0              | 0                 | 0              | 6,035         |
| Sep            | 0          | 0              | 0                 | 0              | 7,527         |
| Oct            | 0          | 0              | 0                 | 0              | 9,810         |
| Nov            | 0          | 0              | 0                 | 0              | 14,264        |
| Dec            | 0          | 0              | 0                 | 0              | 22,027        |
| <b>Totals</b>  | 0          | 0              | 0                 | 0              | 147,695       |

### 4. Billing Demands

| Billing Period | Peak (kW) | Mid-Peak (kW) | Normal Peak (kW) | Off-Peak (kW) | Overall (kW) |
|----------------|-----------|---------------|------------------|---------------|--------------|
| Jan            | 0.0       | 0.0           | 0.0              | 0.0           | 104.7        |
| Feb            | 0.0       | 0.0           | 0.0              | 0.0           | 99.0         |
| Mar            | 0.0       | 0.0           | 0.0              | 0.0           | 72.2         |
| Apr            | 0.0       | 0.0           | 0.0              | 0.0           | 64.9         |
| May            | 0.0       | 0.0           | 0.0              | 0.0           | 56.3         |
| Jun            | 0.0       | 0.0           | 0.0              | 0.0           | 34.4         |
| Jul            | 0.0       | 0.0           | 0.0              | 0.0           | 14.2         |
| Aug            | 0.0       | 0.0           | 0.0              | 0.0           | 36.9         |
| Sep            | 0.0       | 0.0           | 0.0              | 0.0           | 31.5         |
| Oct            | 0.0       | 0.0           | 0.0              | 0.0           | 71.2         |
| Nov            | 0.0       | 0.0           | 0.0              | 0.0           | 75.0         |
| Dec            | 0.0       | 0.0           | 0.0              | 0.0           | 104.5        |

### 5. Maximum Demands

| Billing Period | Peak (kW) | Mid-Peak (kW) | Normal Peak (kW) | Off-Peak (kW) | Overall (kW) |
|----------------|-----------|---------------|------------------|---------------|--------------|
| Jan            | 0.0       | 0.0           | 0.0              | 0.0           | 104.7        |
| Feb            | 0.0       | 0.0           | 0.0              | 0.0           | 99.0         |
| Mar            | 0.0       | 0.0           | 0.0              | 0.0           | 72.2         |
| Apr            | 0.0       | 0.0           | 0.0              | 0.0           | 64.9         |
| May            | 0.0       | 0.0           | 0.0              | 0.0           | 56.3         |
| Jun            | 0.0       | 0.0           | 0.0              | 0.0           | 34.4         |
| Jul            | 0.0       | 0.0           | 0.0              | 0.0           | 14.2         |
| Aug            | 0.0       | 0.0           | 0.0              | 0.0           | 36.9         |
| Sep            | 0.0       | 0.0           | 0.0              | 0.0           | 31.5         |
| Oct            | 0.0       | 0.0           | 0.0              | 0.0           | 71.2         |
| Nov            | 0.0       | 0.0           | 0.0              | 0.0           | 75.0         |
| Dec            | 0.0       | 0.0           | 0.0              | 0.0           | 104.5        |

## Billing Details - Electric - ALT1 - VAV RTU

Project: HAP60-Example-Problem  
Prepared by: Carrier

11/23/2022  
4:10 PM

### 6. Time Of Maximum Demands (Date/Hour)

| Billing Period | Peak | Mid-Peak | Normal Peak | Off-Peak | Overall     |
|----------------|------|----------|-------------|----------|-------------|
| Jan            | n/a  | n/a      | n/a         | n/a      | 1/18 08:00  |
| Feb            | n/a  | n/a      | n/a         | n/a      | 2/4 08:00   |
| Mar            | n/a  | n/a      | n/a         | n/a      | 3/25 06:00  |
| Apr            | n/a  | n/a      | n/a         | n/a      | 4/4 06:00   |
| May            | n/a  | n/a      | n/a         | n/a      | 5/9 06:00   |
| Jun            | n/a  | n/a      | n/a         | n/a      | 6/8 13:00   |
| Jul            | n/a  | n/a      | n/a         | n/a      | 7/16 10:00  |
| Aug            | n/a  | n/a      | n/a         | n/a      | 8/31 13:00  |
| Sep            | n/a  | n/a      | n/a         | n/a      | 9/14 12:00  |
| Oct            | n/a  | n/a      | n/a         | n/a      | 10/25 06:00 |
| Nov            | n/a  | n/a      | n/a         | n/a      | 11/29 07:00 |
| Dec            | n/a  | n/a      | n/a         | n/a      | 12/20 08:00 |

## Monthly Simulation Results for VAV - Wing D

### (In Alternative: ALT1 - VAV RTU)

Project: HAP60-Example-Problem

11/23/2022

Prepared by: Carrier

4:10 PM

#### Air System Simulation Results (Table 1) :

| Month        | Preheat Coil Load (kBTU) | Preheat Coil Input (kWh) | Central Cooling Coil Load (kBTU) | Central Unit Clg Input (kWh) | Terminal Heating Coil Load (kBTU) | Terminal Heating Coil Input (kWh) | Supply Fan (kWh) |
|--------------|--------------------------|--------------------------|----------------------------------|------------------------------|-----------------------------------|-----------------------------------|------------------|
| January      | 30159                    | 8839                     | 336                              | 24                           | 43234                             | 12671                             | 744              |
| February     | 19769                    | 5794                     | 987                              | 72                           | 34647                             | 10154                             | 653              |
| March        | 10198                    | 2989                     | 4969                             | 368                          | 30569                             | 8959                              | 660              |
| April        | 810                      | 237                      | 8770                             | 627                          | 15296                             | 4483                              | 432              |
| May          | 75                       | 22                       | 39311                            | 2819                         | 6413                              | 1880                              | 367              |
| June         | 0                        | 0                        | 53413                            | 3882                         | 1172                              | 343                               | 315              |
| July         | 0                        | 0                        | 18990                            | 1680                         | 0                                 | 0                                 | 182              |
| August       | 0                        | 0                        | 44959                            | 3401                         | 547                               | 160                               | 286              |
| September    | 0                        | 0                        | 45922                            | 3416                         | 1921                              | 563                               | 354              |
| October      | 3251                     | 953                      | 16820                            | 1174                         | 13633                             | 3996                              | 468              |
| November     | 9563                     | 2803                     | 1970                             | 140                          | 26161                             | 7667                              | 586              |
| December     | 23387                    | 6854                     | 137                              | 10                           | 40052                             | 11738                             | 717              |
| <b>Total</b> | <b>97211</b>             | <b>28490</b>             | <b>236582</b>                    | <b>17613</b>                 | <b>213645</b>                     | <b>62613</b>                      | <b>5765</b>      |

#### Air System Simulation Results (Table 2) :

| Month        | Lighting (kWh) | Electric Equipment (kWh) |
|--------------|----------------|--------------------------|
| January      | 1789           | 1422                     |
| February     | 1691           | 1343                     |
| March        | 1929           | 1533                     |
| April        | 1435           | 1139                     |
| May          | 1789           | 1422                     |
| June         | 1564           | 1244                     |
| July         | 296            | 238                      |
| August       | 1218           | 969                      |
| September    | 1780           | 1414                     |
| October      | 1795           | 1425                     |
| November     | 1710           | 1359                     |
| December     | 1509           | 1199                     |
| <b>Total</b> | <b>18507</b>   | <b>14707</b>             |

# **Input Data Reports**



## Design Weather Parameters

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:19 PM

### Design Parameters:

Location ..... **Indianapolis Intl, IN, USA**  
 Latitude ..... **39.73** °N ( + : north, - : south )  
 Longitude ..... **-86.28** °E ( + : east, - : west )  
 Elevation ..... **790.0** ft  
 Climate Zone ..... **4A - Mixed Humid**  
 Local Time Zone ..... **-5.0** hours from GMT ( + : east, - : west )  
 Summer Design Condition ..... **0.4% Cooling**  
 Summer Design Dry-Bulb ..... **91.3** F  
 Summer Coincident Wet-Bulb ..... **75.0** F  
 Summer Daily Range ..... **17.9** F  
 Hottest Month ..... **July**  
 Winter Design Condition ..... **99.6% Heating**  
 Winter Design Dry-Bulb ..... **2.6** F  
 Winter Design Wet-Bulb ..... **0.9** F  
 Outdoor Air CO2 Level ..... **400** ppm  
 Average Ground Reflectance ..... **0.20**  
 Soil Conductivity ..... **0.800** BTU/(hr ft F)  
 Design Cooling Months ..... **May to November**  
 Consider Daylight Savings Time ..... **Yes**  
 Daylight Savings Begins ..... **March 4**  
 Daylight Savings Ends ..... **November 1**  
 Simulation Weather Data ..... **Indianapolis Intl AP (TMYx\_2004\_2018)**  
 Current Data is ..... **ASHRAE Default**

### Design Day Maximum Solar Fluxes

(The flux values are expressed in BTU/(hr sqft) )

| Month      | N     | NNE   | NE    | ENE   | E     | ESE   | SE    | SSE   | S     |
|------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| January    | 21.1  | 21.1  | 26.6  | 106.6 | 173.5 | 234.3 | 267.5 | 283.1 | 283.7 |
| February   | 26.5  | 26.5  | 68.7  | 144.0 | 210.3 | 250.6 | 274.2 | 274.9 | 269.0 |
| March*     | 31.3  | 39.1  | 118.1 | 183.5 | 234.2 | 261.3 | 260.8 | 245.7 | 234.8 |
| April*     | 36.4  | 86.6  | 150.8 | 207.5 | 235.7 | 241.8 | 221.2 | 194.3 | 181.0 |
| May*       | 50.2  | 115.2 | 170.0 | 214.5 | 231.1 | 219.6 | 190.6 | 153.9 | 138.5 |
| June*      | 61.5  | 125.8 | 177.5 | 216.6 | 227.4 | 210.6 | 176.8 | 137.5 | 120.7 |
| July*      | 49.7  | 111.6 | 167.5 | 209.5 | 223.0 | 214.9 | 183.5 | 150.2 | 133.5 |
| August*    | 36.2  | 78.6  | 142.1 | 192.8 | 217.6 | 227.4 | 209.3 | 184.8 | 171.6 |
| September* | 31.7  | 38.5  | 103.3 | 164.7 | 208.1 | 236.5 | 236.8 | 225.3 | 218.3 |
| October*   | 25.5  | 25.5  | 64.3  | 131.8 | 192.6 | 237.6 | 256.5 | 258.1 | 256.9 |
| November   | 20.7  | 20.7  | 32.9  | 95.7  | 170.6 | 221.3 | 260.5 | 274.1 | 276.7 |
| December   | 19.0  | 19.0  | 19.0  | 88.8  | 158.0 | 219.6 | 259.5 | 279.5 | 283.3 |
| Month      | SSW   | SW    | WSW   | W     | WNW   | NW    | NNW   | HOR   | Mult  |
| January    | 282.0 | 265.9 | 235.1 | 171.7 | 106.3 | 29.2  | 21.1  | 161.5 | 1.00  |
| February   | 274.9 | 274.0 | 251.2 | 210.0 | 144.4 | 67.9  | 26.5  | 207.6 | 1.00  |
| March*     | 246.0 | 261.5 | 258.8 | 236.5 | 181.0 | 117.5 | 42.3  | 253.3 | 1.00  |
| April*     | 195.8 | 224.2 | 240.7 | 237.8 | 202.3 | 153.6 | 85.5  | 286.1 | 1.00  |
| May*       | 155.8 | 191.7 | 221.1 | 230.6 | 211.9 | 174.3 | 113.2 | 298.5 | 1.00  |
| June*      | 139.3 | 177.5 | 212.5 | 225.3 | 216.4 | 181.4 | 122.0 | 299.7 | 1.00  |
| July*      | 151.2 | 185.6 | 215.4 | 222.6 | 208.2 | 169.8 | 108.8 | 291.8 | 1.00  |
| August*    | 185.6 | 211.2 | 225.7 | 222.0 | 188.2 | 142.7 | 79.4  | 273.0 | 1.00  |
| September* | 225.0 | 236.6 | 235.2 | 209.9 | 165.6 | 98.9  | 40.7  | 238.6 | 1.00  |
| October*   | 258.2 | 256.6 | 237.5 | 192.8 | 131.5 | 64.4  | 25.5  | 195.9 | 1.00  |
| November   | 273.8 | 260.4 | 222.2 | 170.5 | 94.6  | 33.0  | 20.7  | 156.8 | 1.00  |
| December   | 278.1 | 260.7 | 218.7 | 160.7 | 81.2  | 21.8  | 19.0  | 142.8 | 1.00  |

Mult. = User-defined solar multiplier factor.

\* : Daylight Saving Month

## School Wing D

Project: 860-HAP60-Example-Problem

Prepared by: Carrier

11/21/2022

3:19 PM

### 1. General Information

Building ..... School Wing D  
Default Level-to-Level Height ..... 12'  
Default Floor-to-Ceiling Height ..... 9'  
Default Window Opening Elevation ..... 2' 6"  
Notes ..... None

### 2. Floor Plan Images

#### 2.1. Summary of Floor Plan Images

| Floor Plan Image       | North Orientation (deg) | Scale        | Used in Level(s) |
|------------------------|-------------------------|--------------|------------------|
| High-School-Wing-D.png | 0.0                     | 3/16" = 1'0" | Level 1          |

## School Wing D

Project: 860-HAP60-Example-Problem


Prepared by: Carrier

11/21/2022

3:19 PM

### 2.2. Floor Plan Images

High-School-Wing-D.png:



## School Wing D

Project: 860-HAP60-Example-Problem

Prepared by: Carrier

11/21/2022

3:19 PM

### 3. Levels

#### Summary of Level Data

| Level   | Vertical Position | Override General Defaults | Level-to-Level Height | Floor-to-Ceiling Height | Default Opening Elevation | Ceiling Space Height | Raised Floor Height | Associated Floor Plan Image |
|---------|-------------------|---------------------------|-----------------------|-------------------------|---------------------------|----------------------|---------------------|-----------------------------|
| Level 1 | At-grade          | Yes                       | 12'                   | 9'                      | 2' 6"                     | 3'                   | -                   | High-School-Wing-D.png      |

### 4. Walls & Spaces, Roofs

#### 4.1. Building Summary

| Level   | Space Count | Floor Area (sqft) | Volume (cuft) | Interior Wall Gross Area (sqft) | Exterior Wall Gross Area (sqft) |
|---------|-------------|-------------------|---------------|---------------------------------|---------------------------------|
| Level 1 | 14          | 9274.9            | 83361.8       | 10097.3                         | 3846.6                          |

#### 4.2. Building Summary (Roof Levels)

| Level         | Section Count | Total Roof Area (sqft) | Heat Transfer Area (sqft) | Exterior Wall Gross Area (sqft) |
|---------------|---------------|------------------------|---------------------------|---------------------------------|
| Implied Roofs | 14            | 9274.3                 | 9274.3                    | 0.0                             |

#### 4.3. Space Details

## School Wing D

Project: 860-HAP60-Example-Problem

11/21/2022

Prepared by: Carrier

3:19 PM

| Space                  | Floor Area (sqft) | Volume (cuft) | Interior Wall Gross Area (sqft) | Exterior Wall Gross Area (sqft) | Multi-Level | Notes |
|------------------------|-------------------|---------------|---------------------------------|---------------------------------|-------------|-------|
| Level 1                |                   |               |                                 |                                 |             |       |
| D101 - Classroom       | 873.9             | 7850.4        | 840.3                           | 232.1                           | No          |       |
| D102 - Classroom       | 826.1             | 7421.5        | 827.6                           | 219.4                           | No          |       |
| D103 - Classroom       | 891.8             | 8020.0        | 817.8                           | 264.6                           | No          |       |
| D104 - Classroom       | 890.7             | 8000.1        | 542.1                           | 542.1                           | No          |       |
| D105 - South Vestibule | 64.6              | 580.7         | 204.7                           | 96.7                            | No          |       |
| D106 - Classroom       | 864.2             | 7770.0        | 444.5                           | 616.7                           | No          |       |
| D107 - Classroom       | 876.4             | 7883.5        | 825.2                           | 243.0                           | No          |       |
| D108 - Classroom       | 1713.0            | 15394.8       | 1354.3                          | 211.8                           | No          |       |
| D109 - Practice Room   | 61.2              | 548.0         | 142.2                           | 142.2                           | No          |       |
| D110 - Storage         | 109.7             | 985.3         | 272.2                           | 107.6                           | No          |       |
| D111 - Office          | 146.1             | 1312.3        | 319.7                           | 115.6                           | No          |       |
| D112 - West Vestibule  | 68.0              | 611.2         | 212.9                           | 87.9                            | No          |       |
| D113 - West Corridor   | 949.6             | 8536.2        | 1776.1                          | 0.0                             | No          |       |
| D114 - South Corridor  | 939.5             | 8447.9        | 1517.7                          | 0.0                             | No          |       |
| Ceiling/Floor Spaces   | -                 | 27990.1       | -                               | 966.9                           | -           |       |

### 4.4. Roof Details

## School Wing D

Project: 860-HAP60-Example-Problem

11/21/2022

Prepared by: Carrier

3:19 PM

| Name                                     | Shape | Total Area<br>(sqft) | Heat Transfer<br>Area (sqft) | Pitch   |         | Notes |
|------------------------------------------|-------|----------------------|------------------------------|---------|---------|-------|
|                                          |       |                      |                              | Pitch A | Pitch B |       |
| Level 1                                  |       |                      |                              |         |         |       |
| Ceiling Space for D104 - Classroom       | Flat  | 890.0                | 890.0                        | -       | -       |       |
| Ceiling Space for D105 - South Vestibule | Flat  | 64.6                 | 64.6                         | -       | -       |       |
| Ceiling Space for D107 - Classroom       | Flat  | 877.1                | 877.1                        | -       | -       |       |
| Ceiling Space for D106 - Classroom       | Flat  | 864.4                | 864.4                        | -       | -       |       |
| Ceiling Space for D108 - Classroom       | Flat  | 1712.7               | 1712.7                       | -       | -       |       |
| Ceiling Space for D111 - Office          | Flat  | 146.0                | 146.0                        | -       | -       |       |
| Ceiling Space for D110 - Storage         | Flat  | 109.6                | 109.6                        | -       | -       |       |
| Ceiling Space for D109 - Practice Room   | Flat  | 61.0                 | 61.0                         | -       | -       |       |
| Ceiling Space for D112 - West Vestibule  | Flat  | 68.0                 | 68.0                         | -       | -       |       |
| Ceiling Space for D101 - Classroom       | Flat  | 873.4                | 873.4                        | -       | -       |       |
| Ceiling Space for D103 - Classroom       | Flat  | 892.2                | 892.2                        | -       | -       |       |
| Ceiling Space for D102 - Classroom       | Flat  | 825.7                | 825.7                        | -       | -       |       |
| Ceiling Space for D114 - South Corridor  | Flat  | 939.9                | 939.9                        | -       | -       |       |
| Ceiling Space for D113 - West Corridor   | Flat  | 949.7                | 949.7                        | -       | -       |       |

### 4.5. Unmodeled Space Details

| Unmodeled Spaces | Level   | Notes |
|------------------|---------|-------|
| Unmodeled        | Level 1 |       |

### 4.6. Summary of Wall Groups

| Wall Group | Interior Wall Gross Area (sqft) | Exterior Wall Gross Area (sqft) | Notes |
|------------|---------------------------------|---------------------------------|-------|
| Default    | 9836.5                          | 3846.6                          |       |
| Air Walls  | 260.7                           | 0.0                             |       |

## School Wing D

Project: 860-HAP60-Example-Problem

Prepared by: Carrier

11/21/2022

3:19 PM

### 5. Openings

#### 5.1. Schedule of Window Openings

| Tag | Count | Total Area (sqft) | Width | Height | Elevation | Exterior Shade | Notes                        |
|-----|-------|-------------------|-------|--------|-----------|----------------|------------------------------|
| W01 | 21    | 441.0             | 3' 6" | 6'     | 2' 6"     | None           | Standard size window opening |

#### 5.2. Schedule of Door Openings

| Tag | Count | Total Area (sqft) | Width  | Height | Shade                        | Notes         |
|-----|-------|-------------------|--------|--------|------------------------------|---------------|
| D01 | 2     | 95.4              | 6' 10" | 7'     | Entrance Porch Roof Overhang | Entrance door |

#### 5.3. Schedule of Skylight Openings

None

## School Wing D

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:19 PM

### 1. General Information

Space Model ..... School Wing D  
Building ..... School Wing D  
Notes:

### 2. Spaces

The space model contains 14 spaces with total floor area of 9,275 sqft.

#### 2.1. Ventilation

| Index | Space                  | Level   | Floor Area<br>(sqft) | Space Type               | Ventilation                                       |                  |            |                  |          |                |       |
|-------|------------------------|---------|----------------------|--------------------------|---------------------------------------------------|------------------|------------|------------------|----------|----------------|-------|
|       |                        |         |                      |                          | ASHRAE Standard 62.1-2016<br>Space Usage          | OA Requirement 1 |            | OA Requirement 2 |          | Direct Exhaust |       |
|       |                        |         |                      |                          |                                                   | Airflow          | Units      | Airflow          | Units    | Airflow        | Units |
| 1     | D101 - Classroom       | Level 1 | 873.9                | Classroom - Ages 9+      | EDUCATION: Classroom (age 9 plus)                 | 10.0             | CFM/person | 0.12             | CFM/sqft | 0.0            | CFM   |
| 2     | D102 - Classroom       | Level 1 | 826.1                | Classroom - Ages 9+      | EDUCATION: Classroom (age 9 plus)                 | 10.0             | CFM/person | 0.12             | CFM/sqft | 0.0            | CFM   |
| 3     | D103 - Classroom       | Level 1 | 891.8                | Classroom - Ages 9+      | EDUCATION: Classroom (age 9 plus)                 | 10.0             | CFM/person | 0.12             | CFM/sqft | 0.0            | CFM   |
| 4     | D104 - Classroom       | Level 1 | 890.7                | Classroom - Ages 9+      | EDUCATION: Classroom (age 9 plus)                 | 10.0             | CFM/person | 0.12             | CFM/sqft | 0.0            | CFM   |
| 5     | D105 - South Vestibule | Level 1 | 64.6                 | Corridor - All Others    | GENERAL: Corridor                                 | 0.0              | CFM/person | 0.06             | CFM/sqft | 0.0            | CFM   |
| 6     | D106 - Classroom       | Level 1 | 864.2                | Classroom - Ages 9+      | EDUCATION: Classroom (age 9 plus)                 | 10.0             | CFM/person | 0.12             | CFM/sqft | 0.0            | CFM   |
| 7     | D107 - Classroom       | Level 1 | 876.4                | Classroom - Ages 9+      | EDUCATION: Classroom (age 9 plus)                 | 10.0             | CFM/person | 0.12             | CFM/sqft | 0.0            | CFM   |
| 8     | D108 - Classroom       | Level 1 | 1713.0               | Classroom - Ages 9+      | EDUCATION: Classroom (age 9 plus)                 | 10.0             | CFM/person | 0.12             | CFM/sqft | 0.0            | CFM   |
| 9     | D109 - Practice Room   | Level 1 | 61.2                 | Office - Enclosed, Small | OFFICE: Office space                              | 5.0              | CFM/person | 0.06             | CFM/sqft | 0.0            | CFM   |
| 10    | D110 - Storage         | Level 1 | 109.7                | Storage Room - Medium    | OFFICE: Occupiable storage room for dry materials | 5.0              | CFM/person | 0.06             | CFM/sqft | 0.0            | CFM   |
| 11    | D111 - Office          | Level 1 | 146.1                | Office - Enclosed, Small | OFFICE: Office space                              | 5.0              | CFM/person | 0.06             | CFM/sqft | 0.0            | CFM   |
| 12    | D112 - West Vestibule  | Level 1 | 68.0                 | Corridor - All Others    | GENERAL: Corridor                                 | 0.0              | CFM/person | 0.06             | CFM/sqft | 0.0            | CFM   |
| 13    | D113 - West Corridor   | Level 1 | 949.6                | Corridor - All Others    | GENERAL: Corridor                                 | 0.0              | CFM/person | 0.06             | CFM/sqft | 0.0            | CFM   |
| 14    | D114 - South Corridor  | Level 1 | 939.5                | Corridor - All Others    | GENERAL: Corridor                                 | 0.0              | CFM/person | 0.06             | CFM/sqft | 0.0            | CFM   |



## School Wing D

Project: 860-HAP60-Example-Problem

Prepared by: Carrier

11/21/2022

3:19 PM

### 2.2. Overhead Lighting and Daylighting Control

| Index | Space                  | Overhead Lighting         |                                        |       |        |                                          |                         |              | Daylighting Control |                 |       |
|-------|------------------------|---------------------------|----------------------------------------|-------|--------|------------------------------------------|-------------------------|--------------|---------------------|-----------------|-------|
|       |                        | ASHRAE Standard 90.1-2016 |                                        | Power | Units  | Lighting Type                            | Schedule                | Power Multi. | Control Type        | Illum. Setpoint | Units |
|       |                        | Lighting Method           | Space Usage                            |       |        |                                          |                         |              |                     |                 |       |
| 1     | D101 - Classroom       | Space by Space            | Classroom/Lecture Hall: All others     | 0.92  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 School Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 2     | D102 - Classroom       | Space by Space            | Classroom/Lecture Hall: All others     | 0.92  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 School Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 3     | D103 - Classroom       | Space by Space            | Classroom/Lecture Hall: All others     | 0.92  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 School Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 4     | D104 - Classroom       | Space by Space            | Classroom/Lecture Hall: All others     | 0.92  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 School Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 5     | D105 - South Vestibule | Space by Space            | Corridor: All others                   | 0.66  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 Office Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 6     | D106 - Classroom       | Space by Space            | Classroom/Lecture Hall: All others     | 0.92  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 School Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 7     | D107 - Classroom       | Space by Space            | Classroom/Lecture Hall: All others     | 0.92  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 School Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 8     | D108 - Classroom       | Space by Space            | Classroom/Lecture Hall: All others     | 0.92  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 School Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 9     | D109 - Practice Room   | Space by Space            | Office: Enclosed and <= 250 ft2        | 0.93  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 Office Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 10    | D110 - Storage         | Space by Space            | Storage Room: >= 50 ft2 and <=1000 ft2 | 0.46  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 Office Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 11    | D111 - Office          | Space by Space            | Office: Enclosed and <= 250 ft2        | 0.93  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 Office Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 12    | D112 - West Vestibule  | Space by Space            | Corridor: All others                   | 0.66  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 Office Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 13    | D113 - West Corridor   | Space by Space            | Corridor: All others                   | 0.66  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 Office Lights/Elec | 1.00         | Not Used            | ---             | ---   |
| 14    | D114 - South Corridor  | Space by Space            | Corridor: All others                   | 0.66  | W/sqft | Fluorescent: Recessed, no Lens, Unvented | 90.1 Office Lights/Elec | 1.00         | Not Used            | ---             | ---   |

## School Wing D

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:19 PM

### 2.3. Task Lighting, Electric Equipment and Miscellaneous Heat Gain

| Index | Space                     | Task Lighting |        |          | Electric Equipment |        |                            | Miscellaneous Heat Gain |          |                    |          |
|-------|---------------------------|---------------|--------|----------|--------------------|--------|----------------------------|-------------------------|----------|--------------------|----------|
|       |                           | Power         | Units  | Schedule | Power              | Units  | Schedule                   | Sens.<br>(BTU/hr)       | Schedule | Latent<br>(BTU/hr) | Schedule |
| 1     | D101 - Classroom          | 0.00          | W/sqft | (None)   | 0.90               | W/sqft | 90.1 School<br>Lights/Elec | 0                       | (None)   | 0                  | (None)   |
| 2     | D102 - Classroom          | 0.00          | W/sqft | (None)   | 0.90               | W/sqft | 90.1 School<br>Lights/Elec | 0                       | (None)   | 0                  | (None)   |
| 3     | D103 - Classroom          | 0.00          | W/sqft | (None)   | 0.90               | W/sqft | 90.1 School<br>Lights/Elec | 0                       | (None)   | 0                  | (None)   |
| 4     | D104 - Classroom          | 0.00          | W/sqft | (None)   | 0.90               | W/sqft | 90.1 School<br>Lights/Elec | 0                       | (None)   | 0                  | (None)   |
| 5     | D105 - South<br>Vestibule | 0.00          | W/sqft | (None)   | 0.00               | W/sqft | (None)                     | 0                       | (None)   | 0                  | (None)   |
| 6     | D106 - Classroom          | 0.00          | W/sqft | (None)   | 0.90               | W/sqft | 90.1 School<br>Lights/Elec | 0                       | (None)   | 0                  | (None)   |
| 7     | D107 - Classroom          | 0.00          | W/sqft | (None)   | 0.90               | W/sqft | 90.1 School<br>Lights/Elec | 0                       | (None)   | 0                  | (None)   |
| 8     | D108 - Classroom          | 0.00          | W/sqft | (None)   | 0.90               | W/sqft | 90.1 School<br>Lights/Elec | 0                       | (None)   | 0                  | (None)   |
| 9     | D109 - Practice<br>Room   | 0.00          | W/sqft | (None)   | 0.75               | W/sqft | 90.1 Office<br>Lights/Elec | 0                       | (None)   | 0                  | (None)   |
| 10    | D110 - Storage            | 0.00          | W/sqft | (None)   | 0.00               | W/sqft | (None)                     | 0                       | (None)   | 0                  | (None)   |
| 11    | D111 - Office             | 0.00          | W/sqft | (None)   | 0.75               | W/sqft | 90.1 Office<br>Lights/Elec | 0                       | (None)   | 0                  | (None)   |
| 12    | D112 - West<br>Vestibule  | 0.00          | W/sqft | (None)   | 0.00               | W/sqft | (None)                     | 0                       | (None)   | 0                  | (None)   |
| 13    | D113 - West<br>Corridor   | 0.00          | W/sqft | (None)   | 0.00               | W/sqft | (None)                     | 0                       | (None)   | 0                  | (None)   |
| 14    | D114 - South<br>Corridor  | 0.00          | W/sqft | (None)   | 0.00               | W/sqft | (None)                     | 0                       | (None)   | 0                  | (None)   |

## School Wing D

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:19 PM

### 2.4. Occupancy and Infiltration

| Index | Space                     | Occupants |        |                          |                |                          |                           | Infiltration       |                    |                       |       |            |
|-------|---------------------------|-----------|--------|--------------------------|----------------|--------------------------|---------------------------|--------------------|--------------------|-----------------------|-------|------------|
|       |                           | Occupancy | Units  | Schedule                 | Activity Level | Sens.<br>(BTU/hr/person) | Latent<br>(BTU/hr/person) | Cooling<br>Airflow | Heating<br>Airflow | Simulation<br>Airflow | Units | Occurs     |
| 1     | D101 - Classroom          | 26        | People | 90.1 School<br>Occupancy | User Defined   | 245.0                    | 205.0                     | 0.25               | 0.25               | 0.25                  | ACH   | Unoccupied |
| 2     | D102 - Classroom          | 26        | People | 90.1 School<br>Occupancy | User Defined   | 245.0                    | 205.0                     | 0.25               | 0.25               | 0.25                  | ACH   | Unoccupied |
| 3     | D103 - Classroom          | 26        | People | 90.1 School<br>Occupancy | User Defined   | 245.0                    | 205.0                     | 0.25               | 0.25               | 0.25                  | ACH   | Unoccupied |
| 4     | D104 - Classroom          | 26        | People | 90.1 School<br>Occupancy | User Defined   | 245.0                    | 205.0                     | 0.25               | 0.25               | 0.25                  | ACH   | Unoccupied |
| 5     | D105 - South<br>Vestibule | 0         | People | (None)                   | User Defined   | 245.0                    | 205.0                     | 0.25               | 0.25               | 0.25                  | ACH   | All Hours  |
| 6     | D106 - Classroom          | 26        | People | 90.1 School<br>Occupancy | User Defined   | 245.0                    | 205.0                     | 0.25               | 0.25               | 0.25                  | ACH   | Unoccupied |
| 7     | D107 - Classroom          | 26        | People | 90.1 School<br>Occupancy | User Defined   | 245.0                    | 205.0                     | 0.25               | 0.25               | 0.25                  | ACH   | Unoccupied |
| 8     | D108 - Classroom          | 51        | People | 90.1 School<br>Occupancy | User Defined   | 245.0                    | 205.0                     | 0.25               | 0.25               | 0.25                  | ACH   | Unoccupied |
| 9     | D109 - Practice<br>Room   | 1         | People | 90.1 Office<br>Occupancy | Office Work    | 245.0                    | 205.0                     | 0.25               | 0.25               | 0.25                  | ACH   | Unoccupied |
| 10    | D110 - Storage            | 0         | People | (None)                   | User Defined   | 245.0                    | 205.0                     | 0.25               | 0.25               | 0.25                  | ACH   | Unoccupied |
| 11    | D111 - Office             | 1         | People | 90.1 Office<br>Occupancy | Office Work    | 245.0                    | 205.0                     | 0.25               | 0.25               | 0.25                  | ACH   | Unoccupied |
| 12    | D112 - West<br>Vestibule  | 0         | People | (None)                   | User Defined   | 245.0                    | 205.0                     | 0.25               | 0.25               | 0.25                  | ACH   | All Hours  |
| 13    | D113 - West<br>Corridor   | 0         | People | (None)                   | User Defined   | 245.0                    | 205.0                     | 0.00               | 0.00               | 0.00                  | ACH   | Unoccupied |
| 14    | D114 - South<br>Corridor  | 0         | People | (None)                   | User Defined   | 245.0                    | 205.0                     | 0.00               | 0.00               | 0.00                  | ACH   | Unoccupied |

## School Wing D

Project: 860-HAP60-Example-Problem

Prepared by: Carrier

11/21/2022

3:19 PM

### 3. Zoning

| Zone                      | Space                  | Level   |
|---------------------------|------------------------|---------|
| D101 - Classroom          |                        |         |
|                           | D101 - Classroom       | Level 1 |
| D102 - Classroom          |                        |         |
|                           | D102 - Classroom       | Level 1 |
| D103 - Classroom          |                        |         |
|                           | D103 - Classroom       | Level 1 |
| D104 - Classroom          |                        |         |
|                           | D104 - Classroom       | Level 1 |
| D105 - South Vestibule    |                        |         |
|                           | D105 - South Vestibule | Level 1 |
| D106 - Classroom          |                        |         |
|                           | D106 - Classroom       | Level 1 |
| D107 - Classroom          |                        |         |
|                           | D107 - Classroom       | Level 1 |
| D108 - Classroom          |                        |         |
|                           | D108 - Classroom       | Level 1 |
|                           | D109 - Practice Room   | Level 1 |
|                           | D110 - Storage         | Level 1 |
|                           | D111 - Office          | Level 1 |
| D112 - West Vestibule     |                        |         |
|                           | D112 - West Vestibule  | Level 1 |
| D113 - West Corridor      |                        |         |
|                           | D113 - West Corridor   | Level 1 |
| D114 - South Corridor     |                        |         |
|                           | D114 - South Corridor  | Level 1 |
| Unconditioned (no spaces) |                        |         |

## School Wing D

Project: 860-HAP60-Example-Problem

Prepared by: Carrier

11/21/2022

3:19 PM

| Zone | Space                  | Level |
|------|------------------------|-------|
|      | Unassigned (no spaces) |       |

### 4. Assemblies

| Category                  | Surface Group     | Selected Assembly                          |
|---------------------------|-------------------|--------------------------------------------|
| Exterior Above Grade Wall |                   |                                            |
|                           | Default           | 2016 Zone 4 Above-grade steel-framed wall  |
| Interior Wall             |                   |                                            |
|                           | Default           | Interior Gypsum Board Wall                 |
| Roof                      |                   |                                            |
|                           | Default           | 2016 Zone 4 Insulation entirely above deck |
| Ceiling                   |                   |                                            |
|                           | Interior Ceilings | Acoustic Tile Ceiling                      |
| Slab Floor On Grade       |                   |                                            |
|                           | At-Grade Floors   | 2016 Zone 4 Slab-on-grade floor, unheated  |

### 5. Windows & Doors

| Category | Tag | Width x Height, Elevation | Selected Assembly                               |
|----------|-----|---------------------------|-------------------------------------------------|
| Window   |     |                           |                                                 |
|          | W01 | 3' 6" x 6' , 2' 6"        | 2016 Zone 4 Metal framing, fixed                |
| Door     |     |                           |                                                 |
|          | D01 | 6' 10" x 7'               | 2016 Zone 4 Glass, metal framing, entrance door |

## VAV - Wing D Input Data

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:20 PM

### 1. General Details:

Air System Name ..... VAV - Wing D  
Equipment Type ..... Packaged Rooftop Units  
Air System Type ..... VAV  
Space Model: ..... School Wing D  
Notes:

### 2. System Components:

#### Ventilation Air Data:

Airflow Control ..... Constant Ventilation Airflow  
Ventilation Sizing Method ..... ASHRAE Standard 62.1-2016  
Unocc. Damper Position ..... Closed  
Damper Leak Rate ..... 5 %

#### Economizer Data:

Control ..... Integrated enthalpy control  
Upper Cutoff ..... 73.0 F  
Lower Cutoff ..... -60.0 F

#### Preheat Coil Data:

Setpoint ..... 52.0 F  
Heating Source ..... Electric Resistance  
Schedule ..... JFMAMJJASOND  
Coil position ..... Downstream of Mixing Point

#### Central Cooling Data:

Supply Air Temperature ..... 55.0 F  
Cooling Source ..... Air-Cooled DX  
Schedule ..... JFMAMJJASOND  
Capacity Control ..... Constant Temperature - Fan On

#### Supply Fan Data:

Fan Type ..... Forward Curved with VFD  
Configuration ..... Draw-thru  
Fan Performance ..... 2.00 in wg  
Overall Efficiency ..... 54 %

|           |     |    |    |    |    |    |
|-----------|-----|----|----|----|----|----|
| % Airflow | 100 | 90 | 80 | 70 | 60 | 50 |
| % kW      | 100 | 77 | 60 | 44 | 35 | 25 |

|           |    |    |    |    |   |
|-----------|----|----|----|----|---|
| % Airflow | 40 | 30 | 20 | 10 | 0 |
| % kW      | 19 | 13 | 9  | 7  | 6 |

#### Duct System Data:

##### Supply Duct Data:

Duct Leakage ..... 0 %

##### Return Duct or Plenum Data:

Return Air Via ..... Ducted Return

## VAV - Wing D Input Data

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:20 PM

### 3. Zone Components:

#### Assigned Zones:

| Zone | Zone Name              |
|------|------------------------|
| 1    | D101 - Classroom       |
| 2    | D102 - Classroom       |
| 3    | D103 - Classroom       |
| 4    | D104 - Classroom       |
| 5    | D105 - South Vestibule |
| 6    | D106 - Classroom       |
| 7    | D107 - Classroom       |
| 8    | D108 - Classroom       |
| 9    | D112 - West Vestibule  |
| 10   | D113 - West Corridor   |
| 11   | D114 - South Corridor  |

Number of zones ..... 11

#### Thermostats and Zone Data:

| Zone | Cooling<br>T-Stat<br>Occ.<br>(F) | Cooling<br>T-Stat<br>Unocc.<br>(F) | Heating<br>T-Stat<br>Occ.<br>(F) | Heating<br>T-Stat<br>Unocc.<br>(F) | T-Stat<br>Throttling<br>Range<br>(F) | Diversity<br>Factor<br>(%) | Direct<br>Exhaust<br>Fan<br>(kW) |
|------|----------------------------------|------------------------------------|----------------------------------|------------------------------------|--------------------------------------|----------------------------|----------------------------------|
| 1    | 75.0                             | 80.0                               | 70.0                             | 65.0                               | 1.50                                 | 100                        | 0.0                              |
| 2    | 75.0                             | 80.0                               | 70.0                             | 65.0                               | 1.50                                 | 100                        | 0.0                              |
| 3    | 75.0                             | 80.0                               | 70.0                             | 65.0                               | 1.50                                 | 100                        | 0.0                              |
| 4    | 75.0                             | 80.0                               | 70.0                             | 65.0                               | 1.50                                 | 100                        | 0.0                              |
| 5    | 75.0                             | 80.0                               | 70.0                             | 65.0                               | 1.50                                 | 100                        | 0.0                              |
| 6    | 75.0                             | 80.0                               | 70.0                             | 65.0                               | 1.50                                 | 100                        | 0.0                              |
| 7    | 75.0                             | 80.0                               | 70.0                             | 65.0                               | 1.50                                 | 100                        | 0.0                              |
| 8    | 75.0                             | 80.0                               | 70.0                             | 65.0                               | 1.50                                 | 100                        | 0.0                              |
| 9    | 75.0                             | 80.0                               | 70.0                             | 65.0                               | 1.50                                 | 100                        | 0.0                              |
| 10   | 75.0                             | 80.0                               | 70.0                             | 65.0                               | 1.50                                 | 100                        | 0.0                              |
| 11   | 75.0                             | 80.0                               | 70.0                             | 65.0                               | 1.50                                 | 100                        | 0.0                              |

Thermostat Schedule ..... Fan / Thermostat  
Unoccupied Cooling is ..... Available

## VAV - Wing D Input Data

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:20 PM

### Supply Terminals Data:

| Zone | Terminal Type                  | Air Distribution                | Air Distribution Effectiveness Specification | Air Distribution Effectiveness | Minimum Airflow | Design Supply Temp. | Fan Perf. | Fan Efficiency |
|------|--------------------------------|---------------------------------|----------------------------------------------|--------------------------------|-----------------|---------------------|-----------|----------------|
| 1    | VAV box with RH (Dual Maximum) | Ceiling supply / ceiling return | ASHRAE 62.1                                  | <auto>                         | 25 %            | 90.0 F              | -         | -              |
| 2    | VAV box with RH (Dual Maximum) | Ceiling supply / ceiling return | ASHRAE 62.1                                  | <auto>                         | 25 %            | 90.0 F              | -         | -              |
| 3    | VAV box with RH (Dual Maximum) | Ceiling supply / ceiling return | ASHRAE 62.1                                  | <auto>                         | 25 %            | 90.0 F              | -         | -              |
| 4    | VAV box with RH (Dual Maximum) | Ceiling supply / ceiling return | ASHRAE 62.1                                  | <auto>                         | 25 %            | 90.0 F              | -         | -              |
| 5    | VAV box with RH (Dual Maximum) | Ceiling supply / ceiling return | ASHRAE 62.1                                  | <auto>                         | 25 %            | 90.0 F              | -         | -              |
| 6    | VAV box with RH (Dual Maximum) | Ceiling supply / ceiling return | ASHRAE 62.1                                  | <auto>                         | 25 %            | 90.0 F              | -         | -              |
| 7    | VAV box with RH (Dual Maximum) | Ceiling supply / ceiling return | ASHRAE 62.1                                  | <auto>                         | 25 %            | 90.0 F              | -         | -              |
| 8    | VAV box with RH (Dual Maximum) | Ceiling supply / ceiling return | ASHRAE 62.1                                  | <auto>                         | 25 %            | 90.0 F              | -         | -              |
| 9    | VAV box with RH (Dual Maximum) | Ceiling supply / ceiling return | ASHRAE 62.1                                  | <auto>                         | 25 %            | 90.0 F              | -         | -              |
| 10   | VAV box with RH (Dual Maximum) | Ceiling supply / ceiling return | ASHRAE 62.1                                  | <auto>                         | 25 %            | 90.0 F              | -         | -              |
| 11   | VAV box with RH (Dual Maximum) | Ceiling supply / ceiling return | ASHRAE 62.1                                  | <auto>                         | 25 %            | 90.0 F              | -         | -              |

Reheat Coil Source ..... Electric Resistance  
Reheat Coil Schedule ..... JFMAMJJASOND

### 4. Sizing Data (Computer-Generated):

#### System Sizing Data:

##### Sizing Data:

Cooling Supply Temperature ..... 55.0 F  
Supply Fan Airflow ..... 6433.6 CFM  
Ventilation Airflow ..... 3882.3 CFM

##### Hydronic Sizing Specifications:

Chilled Water Supply Temperature ..... 44.0 F  
Chilled Water Delta-T ..... 10.0 F  
Hot Water Supply Temperature ..... 140.0 F  
Hot Water Delta-T ..... 20.0 F

##### Safety Factors:

Cooling Sensible ..... 0 %  
Cooling Latent ..... 0 %  
Heating ..... 0 %

### Zone Sizing Data:

Zone Airflow Sizing Method ..... Peak zone sensible load  
Space Airflow Sizing Method ..... Individual peak space loads

| Zone | Supply Airflow (CFM) | Zone Htg Unit (MBH) | Reheat Coil (MBH) | FPMBX Fan (CFM) |
|------|----------------------|---------------------|-------------------|-----------------|
| 1    | 741.3                | -                   | 16.8              | -               |
| 2    | 724.1                | -                   | 16.5              | -               |
| 3    | 748.8                | -                   | 16.9              | -               |



## VAV - Wing D Input Data

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:20 PM

| Zone | Supply Airflow<br>(CFM) | Zone Htg Unit<br>(MBH) | Reheat Coil<br>(MBH) | FPMBX Fan<br>(CFM) |
|------|-------------------------|------------------------|----------------------|--------------------|
| 4    | 750.9                   | -                      | 16.8                 | -                  |
| 5    | 128.1                   | -                      | 4.7                  | -                  |
| 6    | 842.5                   | -                      | 16.7                 | -                  |
| 7    | 803.0                   | -                      | 16.8                 | -                  |
| 8    | 1470.1                  | -                      | 34.2                 | -                  |
| 9    | 136.7                   | -                      | 5.0                  | -                  |
| 10   | 270.4                   | -                      | 3.5                  | -                  |
| 11   | 253.6                   | -                      | 3.2                  | -                  |

### 5. Equipment Data

#### Central Cooling Unit - Air-Cooled DX

Estimated Maximum Load ..... **360.5** MBH  
 Design OADB ..... **95.0** F  
 Design EWB ..... **67.0** F  
 Equipment Sizing ..... **(Auto-Sized) 414.6** MBH  
 Capacity Oversizing Factor ..... **15** %  
 AHRI Performance Rating ..... **10.000** EER  
 DX System Configuration ..... **3-stage, 3 compressors, 2 circuits**  
 Low Temperature Cutoff OAT ..... **0.0** F

## ALT1 - VAV RTU Input Data

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:20 PM

### 1. General Details:

Name ..... ALT1 - VAV RTU  
Energy Sim. Status ..... Calculated

### 2. Plants Included in this Alternative:

(none)

### 3. Air Systems Included in this Alternative:

| Air System   | # Zones |
|--------------|---------|
| VAV - Wing D | 11      |

### 4. Space Models Included in this Alternative:

#### Summary Calculation Status:

Design Sizing ..... Calculated  
Energy Simulation ..... Calculated

#### Space Model: School Wing D (for School Wing D)

Design Sizing ..... Calculated  
Energy Simulation ..... Calculated

| Zone                   | Air System   |
|------------------------|--------------|
| D101 - Classroom       | VAV - Wing D |
| D102 - Classroom       | VAV - Wing D |
| D103 - Classroom       | VAV - Wing D |
| D104 - Classroom       | VAV - Wing D |
| D105 - South Vestibule | VAV - Wing D |
| D106 - Classroom       | VAV - Wing D |
| D107 - Classroom       | VAV - Wing D |
| D108 - Classroom       | VAV - Wing D |
| D112 - West Vestibule  | VAV - Wing D |
| D113 - West Corridor   | VAV - Wing D |
| D114 - South Corridor  | VAV - Wing D |

### 5. Miscellaneous Energy

(no items defined)

### 6. Meters

Electric ..... Indiana - EIA 2020

### 7. Miscellaneous Data

Average Building Power Factor ..... 100.00 %  
Source Electric Generating Efficiency ..... 28.00 %  
Additional Floor Area ..... 0.0 sqft

## Schedule Input Data

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:21 PM

### 90.1 Office Lights/Elec (Fractional)

#### Hourly Profiles:

##### Design Day

| Hour  | 00 | 01 | 02 | 03 | 04 | 05  | 06  | 07  | 08  | 09  | 10  | 11  | 12  | 13  | 14  | 15  | 16  | 17  | 18  | 19  | 20  | 21  | 22  | 23 |
|-------|----|----|----|----|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|
| Value | 5  | 5  | 5  | 5  | 5  | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 5  |

##### Weekday

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Value | 5  | 5  | 5  | 5  | 5  | 10 | 10 | 30 | 90 | 90 | 90 | 90 | 80 | 90 | 90 | 90 | 90 | 50 | 30 | 30 | 20 | 20 | 10 | 5  |

##### Saturday

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Value | 5  | 5  | 5  | 5  | 5  | 5  | 10 | 10 | 30 | 30 | 30 | 30 | 15 | 15 | 15 | 15 | 15 | 5  | 5  | 5  | 5  | 5  | 5  | 5  |

##### Sunday

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Value | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  |

#### Assignments:

|           | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|-----------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Design    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   |
| Monday    | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Tuesday   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Wednesday | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Thursday  | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Friday    | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Saturday  | 3   | 3   | 3   | 3   | 3   | 3   | 2   | 3   | 3   | 3   | 3   | 3   |
| Sunday    | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   |
| Holiday   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   |

### 90.1 Office Occupancy (Fractional)

#### Hourly Profiles:

##### Design Day

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06  | 07  | 08  | 09  | 10  | 11  | 12  | 13  | 14  | 15  | 16  | 17  | 18  | 19  | 20  | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|----|
| Value | 0  | 0  | 0  | 0  | 0  | 0  | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 0  | 0  |    |

##### Weekday

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Value | 0  | 0  | 0  | 0  | 0  | 0  | 10 | 20 | 95 | 95 | 95 | 95 | 50 | 95 | 95 | 95 | 95 | 30 | 10 | 10 | 10 | 10 | 5  | 5  |

##### Saturday

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Value | 0  | 0  | 0  | 0  | 0  | 0  | 10 | 10 | 30 | 30 | 30 | 30 | 10 | 10 | 10 | 10 | 10 | 5  | 5  | 0  | 0  | 0  | 0  | 0  |

##### Sunday

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Value | 0  | 0  | 0  | 0  | 0  | 0  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 0  | 0  | 0  | 0  | 0  | 0  |

## Schedule Input Data

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:21 PM

### Assignments:

|           | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|-----------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Design    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   |
| Monday    | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Tuesday   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Wednesday | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Thursday  | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Friday    | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Saturday  | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   |
| Sunday    | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   |
| Holiday   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   |

### 90.1 School Lights/Elec (Fractional)

#### Hourly Profiles:

##### Design Day

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07  | 08  | 09  | 10  | 11  | 12  | 13  | 14  | 15  | 16  | 17  | 18  | 19  | 20  | 21  | 22 | 23 |
|-------|----|----|----|----|----|----|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|
| Value | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 5  | 5  |

##### Weekday

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Value | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 30 | 85 | 95 | 95 | 95 | 80 | 80 | 80 | 70 | 50 | 50 | 35 | 35 | 35 | 30 | 5  | 5  |

##### Saturday

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Value | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 15 | 15 | 15 | 15 | 15 | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  |

##### Sunday

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Value | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  | 5  |

### Assignments:

|           | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|-----------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Design    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   |
| Monday    | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Tuesday   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Wednesday | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Thursday  | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Friday    | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| Saturday  | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   |
| Sunday    | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   |
| Holiday   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   |

### 90.1 School Occupancy (Fractional)

#### Hourly Profiles:

##### Design Day

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07  | 08  | 09  | 10  | 11  | 12  | 13  | 14  | 15  | 16  | 17  | 18  | 19  | 20  | 21  | 22 | 23 |
|-------|----|----|----|----|----|----|----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|
| Value | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 0  | 0  |

##### Weekday

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Value | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 5  | 75 | 90 | 90 | 80 | 80 | 80 | 80 | 45 | 15 | 5  | 15 | 20 | 20 | 10 | 0  | 0  |

##### Saturday

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Value | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 10 | 10 | 10 | 10 | 10 | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  |

##### Sunday

| Hour  | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|-------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Value | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  | 0  |

## Schedule Input Data

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:21 PM

### Assignments:

|                  | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| <b>Design</b>    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   |
| <b>Monday</b>    | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| <b>Tuesday</b>   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| <b>Wednesday</b> | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| <b>Thursday</b>  | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| <b>Friday</b>    | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| <b>Saturday</b>  | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   |
| <b>Sunday</b>    | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   |
| <b>Holiday</b>   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   |

### Fan / Thermostat (Fan / Thermostat)

#### Hourly Profiles:

##### Design Day

| Hour         | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|--------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| <b>Value</b> | U  | U  | U  | U  | U  | U  | U  | O  | O  | O  | O  | O  | O  | O  | O  | O  | O  | O  | O  | O  | O  | O  | U  | U  |

##### Weekday

| Hour         | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|--------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| <b>Value</b> | U  | U  | U  | U  | U  | U  | U  | O  | O  | O  | O  | O  | O  | O  | O  | O  | O  | O  | O  | O  | O  | O  | U  | U  |

##### Saturday

| Hour         | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|--------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| <b>Value</b> | U  | U  | U  | U  | U  | U  | U  | U  | O  | O  | O  | O  | O  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  |

##### Sunday

| Hour         | 00 | 01 | 02 | 03 | 04 | 05 | 06 | 07 | 08 | 09 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 |
|--------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| <b>Value</b> | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  | U  |

O = Occupied; U = Unoccupied

### Assignments:

|                  | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| <b>Design</b>    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   |
| <b>Monday</b>    | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| <b>Tuesday</b>   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| <b>Wednesday</b> | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| <b>Thursday</b>  | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| <b>Friday</b>    | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   | 2   |
| <b>Saturday</b>  | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   | 3   |
| <b>Sunday</b>    | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   |
| <b>Holiday</b>   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   | 4   |

## Wall Constructions

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:22 PM

### 2016 Zone 4 Above-grade steel-framed wall

Wall Type ..... Exterior, Above Grade Wall  
Inside Surface Color ..... Light  
Inside Absorptivity ..... 0.450  
Outside Surface Color ..... Medium  
Outside Absorptivity ..... 0.675  
Overall U-Value ..... 0.064 BTU/(hr sqft F)

#### Wall Assembly Layers - (Inside Space to Outside)

| Layers                                              | Thickness<br>in | Density<br>lb/cuft | Specific Heat<br>BTU / (lb F) | R-Value<br>(hr sqft<br>F)/BTU | Weight<br>lb/sqft |
|-----------------------------------------------------|-----------------|--------------------|-------------------------------|-------------------------------|-------------------|
| Inside Surface Resistance                           |                 |                    |                               | 0.68000                       |                   |
| 5/8-in gypsum board                                 | 0.625           | 50.0               | 0.26                          | 0.56306                       | 2.6               |
| 3.5-in cavity, 16-in o.c. steel frame,<br>R-13 batt | 3.500           | 3.4                | 0.20                          | 6.00000                       | 1.0               |
| R-7.5 board insulation                              | 1.500           | 2.5                | 0.35                          | 7.50000                       | 0.3               |
| 5/8-in gypsum board                                 | 0.625           | 50.0               | 0.26                          | 0.56306                       | 2.6               |
| 3/4-in HW stucco                                    | 0.750           | 120.0              | 0.20                          | 0.08000                       | 7.5               |
| Outside Surface Resistance                          |                 |                    |                               | 0.17000                       |                   |
| <b>Totals</b>                                       | <b>7.000</b>    | <b>-</b>           | <b>-</b>                      | <b>15.55612</b>               | <b>14.0</b>       |

### Interior Gypsum Board Wall

Wall Type ..... Interior Wall  
Inside Surface Color ..... Light  
Inside Absorptivity ..... 0.450  
Outside Surface Color ..... Light  
Outside Absorptivity ..... 0.450  
Overall U-Value ..... 0.305 BTU/(hr sqft F)

#### Wall Assembly Layers - (Inside Space to Outside Space)

| Layers                                             | Thickness<br>in | Density<br>lb/cuft | Specific Heat<br>BTU / (lb F) | R-Value<br>(hr sqft<br>F)/BTU | Weight<br>lb/sqft |
|----------------------------------------------------|-----------------|--------------------|-------------------------------|-------------------------------|-------------------|
| Inside Surface Resistance                          |                 |                    |                               | 0.68000                       |                   |
| 5/8-in gypsum board                                | 0.625           | 50.0               | 0.26                          | 0.56306                       | 2.6               |
| 3.5-in cavity, 16-in o.c. steel frame, no<br>insul | 3.500           | 2.9                | 0.01                          | 0.79000                       | 0.8               |
| 5/8-in gypsum board                                | 0.625           | 50.0               | 0.26                          | 0.56306                       | 2.6               |
| Outside Surface Resistance                         |                 |                    |                               | 0.68000                       |                   |
| <b>Totals</b>                                      | <b>4.750</b>    | <b>-</b>           | <b>-</b>                      | <b>3.27612</b>                | <b>6.0</b>        |

## Roof Constructions

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:22 PM

### 2016 Zone 4 Insulation entirely above deck

Inside Surface Color ..... **Light**  
Inside Absorptivity ..... **0.450**  
Outside Surface Color ..... **Medium**  
Outside Absorptivity ..... **0.675**  
Overall U-Value ..... **0.032** BTU/(hr sqft F)

### Roof Assembly Layers - (Outside to Inside Space)

| Layers                     | Thickness<br>in | Density<br>lb/cuft | Specific Heat<br>BTU / (lb F) | R-Value<br>(hr sqft<br>F)/BTU | Weight<br>lb/sqft |
|----------------------------|-----------------|--------------------|-------------------------------|-------------------------------|-------------------|
| Outside Surface Resistance |                 |                    |                               | 0.17000                       |                   |
| R-30 board insulation      | 6.000           | 2.5                | 0.35                          | 30.00000                      | 1.3               |
| 22-gauge steel roof deck   | 0.034           | 489.0              | 0.12                          | 0.00009                       | 1.4               |
| Inside Surface Resistance  |                 |                    |                               | 0.61000                       |                   |
| <b>Totals</b>              | <b>6.034</b>    | <b>-</b>           | <b>-</b>                      | <b>30.78009</b>               | <b>2.6</b>        |

## Ceiling Constructions

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:22 PM

### Acoustic Tile Ceiling

Inside Surface Color ..... **Light**  
Inside Absorptivity ..... **0.450**  
Outside Surface Color ..... **Light**  
Outside Absorptivity ..... **0.450**  
Overall U-Value ..... **0.350** BTU/(hr sqft F)

### Ceiling Assembly Layers - (Outside Space to Inside Space)

| Layers                     | Thickness<br>in | Density<br>lb/cuft | Specific Heat<br>BTU / (lb F) | R-Value<br>(hr sqft<br>F)/BTU | Weight<br>lb/sqft |
|----------------------------|-----------------|--------------------|-------------------------------|-------------------------------|-------------------|
| Outside Surface Resistance |                 |                    |                               | 0.46000                       |                   |
| Acoustic Tile              | 0.750           | 23.0               | 0.14                          | 1.78571                       | 1.4               |
| Inside Surface Resistance  |                 |                    |                               | 0.61000                       |                   |
| <b>Totals</b>              | <b>0.750</b>    | <b>-</b>           | <b>-</b>                      | <b>2.85571</b>                | <b>1.4</b>        |



## Floor Constructions

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:22 PM

### 2016 Zone 4 Slab-on-grade floor, unheated

Floor Type ..... **Slab Floor On Grade**  
Inside Surface Color ..... **Medium**  
Inside Absorptivity ..... **0.675**  
Overall U-Value ..... **0.733** BTU/(hr sqft F)

#### Floor Assembly Layers - (Inside Space to Soil)

| Layers                    | Thickness<br>in | Density<br>lb/cuft | Specific Heat<br>BTU / (lb F) | R-Value<br>(hr sqft<br>F)/BTU | Weight<br>lb/sqft |
|---------------------------|-----------------|--------------------|-------------------------------|-------------------------------|-------------------|
| Inside Surface Resistance |                 |                    |                               | 0.92000                       |                   |
| 6 in. HW concrete         | 6.000           | 140.0              | 0.22                          | 0.44444                       | 70.0              |
| <b>Totals</b>             | <b>6.000</b>    | <b>-</b>           | <b>-</b>                      | <b>1.36444</b>                | <b>70.0</b>       |

#### Exterior Insulation

Configuration ..... **Horizontal Exterior Insulation**  
Horizontal Insulation Extends Inward from Slab Perimeter ..... **2.00** ft

| Exterior Insulation Layer | Thickness<br>in | Density<br>lb/cuft | Specific Heat<br>BTU / (lb F) | R-Value<br>(hr sqft<br>F)/BTU | Weight<br>lb/sqft |
|---------------------------|-----------------|--------------------|-------------------------------|-------------------------------|-------------------|
| R-15 board insulation     | 3.000           | 2.5                | 0.35                          | 15.00000                      | 0.6               |

## Window Constructions

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:23 PM

### 2016 Zone 4 Metal framing, fixed

---

Input Method ..... Simple input method

#### Window Performance:

|                       |       |                 |
|-----------------------|-------|-----------------|
| Overall U-Value ..... | 0.380 | BTU/(hr sqft F) |
| Overall SHGC .....    | 0.360 |                 |
| Overall VT .....      | 0.396 |                 |

#### Internal Shade:

Type ..... None

## Door Constructions

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:23 PM

### 2016 Zone 4 Glass, metal framing, entrance door

---

|                     |                   |                 |
|---------------------|-------------------|-----------------|
| Door Type .....     | <b>Glass Door</b> |                 |
| Glass U-Value ..... | <b>0.680</b>      | BTU/(hr sqft F) |
| Glass SHGC .....    | <b>0.360</b>      |                 |
| Glass VT .....      | <b>0.396</b>      |                 |

# Exterior Shades

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:23 PM

## Entrance Porch Roof Overhang

Reveal Depth..... 0.0 in

### Left Fin:

Projection from surface..... 0.0 in  
Height above window ..... 0.0 in  
Dist. from edge of window ..... 0.0 in

### Overhang:

Projection from surface ..... 72.0 in  
Height above window ..... 12.0 in  
Ext. past RH side of window..... 12.0 in  
Ext. past LH side of window ..... 12.0 in

### Right Fin:

Projection from surface ..... 0.0 in  
Height above window ..... 0.0 in  
Dist. from edge of window ..... 0.0 in

## Electric Rate Input Data

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:23 PM

### Indiana - EIA 2020

#### General Details

Rate Name ..... **Indiana - EIA 2020**  
Rate Type ..... **Complex**  
Energy Units ..... **kWh**  
Conversion ..... **1.00000** kWh/kWh  
Demand Units ..... **kW**  
Customer Charge ..... **0.00** \$  
Minimum Charge ..... **0.00** \$  
Tax Rate ..... **0.00** %

#### Emissions Analysis

CO2e Factor ..... **1.67** lb/kWh

#### Energy Charges

Type of Energy Charge ..... **Standard**

| Step Type | Season      | Period      | Block Size | Block Units | \$/kWh  |
|-----------|-------------|-------------|------------|-------------|---------|
| Energy    | All Seasons | All Periods | 9999999    | kWh         | 0.11210 |

#### Demand Clauses

No data specified. ....

## Fuel Rate Input Data

Project: 860-HAP60-Example-Problem  
Prepared by: Carrier

11/21/2022  
3:24 PM

### Indiana - EIA 2020

#### General Details

Rate Name ..... **Indiana - EIA 2020**  
Rate Type ..... **Simple**  
Energy Units ..... **MCF**  
Conversion ..... **1000.00000** kBTU/MCF  
Demand Units ..... **Hourly Peak**  
Flat Price ..... **6.86000** \$/MCF  
Customer Charge ..... **0.00** \$  
Minimum Charge ..... **0.00** \$  
Tax Rate ..... **0.00** %

#### Emissions Analysis

CO2e Factor ..... **123.00** lb/MCF